



545 E Algonquin Road, Suite H
Arlington Heights, IL 60005

Telephone: 847-439-5667
www.intertek.com

PUBLIC NOTICE

Intertek Warns of Counterfeit Documents: Claim of compliance to **ANSI/UL 943 Ed. 4** and **CSA C22.2 No. 144-06** for **Premium Power Controls Receptacle type Ground-Fault Circuit-Interrupters**

Published: May 31, 2016

The following is a notification from Intertek that the document identified below is counterfeit and the claims made or implied from the document is unknown. Products and services referred to have not been evaluated by Intertek.

Document Description	<p><i>Receptacle type Ground-Fault Circuit-Interrupters with brand name Hangon for model GL-01, GL-02, GL-03, GL-04, GL-05, GL-06, GL-07.</i></p> <p><i>The products are certified by Intertek with ETL report no. SH12051401-001 dated 5-Dec-2012 to standards ANSI/UL 943 Ed. 4 dated 2006/02/01, Rev:2012/06/29 and CSA C22.2 No. 144-06</i></p>
Applicant Name	<i>Premium Power Controls</i>
Reported Hazards	<i>Unknown</i>



AUTHORIZATION TO MARK

COUNTERFEIT

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple (size model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Premium Power Controls	Manufacturer: Fujian Hongan Electric Co., Ltd.
Address: 3518 Gleneagles Drive, Stockton, CA 95219	Address: Yantian Industrial Zone, Xiapu, Ningde, Fujian, 355106 (325604)
Country: USA	Country: China
Contact: Ziggy Chen	Contact: WenLe Chen
Phone: 86-18667737333	Phone: 86-577-62710007
FAX:	FAX:
Email: chenpz527@gmail.com	Email: jlc-0312@163.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services Shanghai L^{td}

Control Number: 4006672 **Authorized by:** 
 William T. Stan, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek Client and is provided pursuant to the Certification Agreement between Intertek and the Client. Intertek's responsibility and liability are limited to the terms and conditions of the Agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement. No any time, Intertek is not responsible for the use of the Authorization to Mark. Only the Client is authorized to permit copying or distribution of the Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions set out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or endorsement of the product, service, printed or service mark that the approval is not by Intertek, other Party Agreements and Policies. Intertek reserves the right to withdraw or terminate the Authorization to Mark at any time without notice. Intertek is not responsible for the purchase of production quality control and does not release the Client of their obligations in this regard.

Intertek Testing Services NA Inc.
 165 Main Street, Fairfield, NJ 07004
 Telephone 800-345-3851 or 907-753-8711 Fax 907-756-8899

Standard(s):	Ground-Fault Circuit-Interrupters ANSI/UL 943 Ed. 4 dated 2006/02/01, Rev:2012/06/29 and CSA C22.2 No. 144-06
Product:	Receptacle type Ground-Fault Circuit-Interrupters
Brand Name:	Hongan
Models:	GL-01, GL-02, GL-03, GL-04, GL-05, GL-06, GL-07.