

STANDARD INFORMATION

Standard: CSA C22.2 No. 269.2

Standard ID: Surge Protective Devices - Type 2 - Permanently Connected [CSA C22.2#269.2:2017 Ed.2]

Previous Standard ID: Surge Protective Devices - Type 2 - Permanently Connected [CSA C22.2#269.2:2013 Ed.1]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **February 1, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes:

- New definition for Moulded case SPD
- New requirements for Moulded case SPD
- New marking requirements for Moulded case SPD

Specific details of new/revISED requirements are found in table below

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
3	Info	Definitions and abbreviations
		Definitions
3.1	Info	The following definitions shall apply in this Standard: Moulded case SPD — a one-port SPD incorporated within a moulded case and intended for use in a space within a panelboard normally occupied by a branch circuit breaker complying with CSA C22.2 No. 5.
4	Info	Construction
4.1	Info	General
		<i>New clause added;</i>
4.1.4		Moulded case SPDs shall additionally comply with the applicable construction requirements in CSA C22.2 No. 5 including, but not limited to, electrical spacings, wiring space and wire bending space.
5	Info	Documentation, ratings, and markings
		<i>New clause added;</i>
5.4		Unless the proper wiring connections are plainly evident, wiring terminals shall be marked, or the equipment shall be provided with a suitable wiring diagram to indicate the connections. Moulded case SPDs shall be marked with the applicable termination markings as required by CSA C22.2 No. 5.
		<i>New clause added;</i>
5.9		An SPD that is used with internal or external field-replaceable fuses shall be marked to indicate the type, ampere, and voltage rating of the replacement fuses. For moulded case SPDs, the location of the marking shall be in accordance with the “location categories” requirements in CSA C22.2 No. 5.
		<i>New clause added;</i>
5.10		An SPD that is used with external circuit breakers shall have the maximum circuit breaker interrupting rating and nominal voltage marked. For moulded case SPDs, the location of the marking shall be in accordance with the “location categories” requirements in CSA C22.2 No. 5.