

STANDARD INFORMATION

Standard: NSF/ANSI/CAN 372

Standard ID: Drinking Water System Components - Lead Content [NSF/ANSI/CAN 372:2024]

Previous Standard ID: Drinking Water System Components - Lead Content [NSF/ANSI/CAN 372:2022]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **December 1, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Revisions to align with 40 CFR § 143 Subpart B (US EPA Final Lead Rule). Specific details of new/updated requirements are found in table below.

Note: If the listing references a Canadian standard, per the Canadian Electrical Code (CSA C22.2#0) Section titled Language of markings, Caution and Warning Markings shall be in English and French.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
2	Info	Definitions
	Info	drinking water cooler: Any mechanical device, affixed to drinking water supply plumbing, which actively cools water for human consumption. Source of definition: 40 CFR § 143 Subpart B, Use of Lead Free Pipes, Fittings, Fixtures, Solder, and Flux for Drinking Water.
3	Info	General requirements
		Solders and fluxes shall have a lead content less than or equal to 0.2%. <u>The storage tank interior surface of drinking water coolers shall have a lead content less than or equal to 0.2%. Drinking water coolers must be manufactured such that each individual part or component that may come in contact with drinking water shall not contain more than 8% lead.</u> All products shall have a weighted average lead content less than or equal to 0.25% based on the average of their wetted surface areas.